

OUTDOOR HEATING/RESTAURANTS

FIRE PITS and LP (LIQUID PROPANE) fire pits are NOT PERMITTED

LP GAS TYPE HEATERS are PERMITTED under the following guidelines:

LP gas heaters are NOT to be used in buildings including tents, (in and under them) partially covered canopy type enclosures, foyers and enclosed courtyards.

The unit shall NOT be left unattended.

The unit shall be placed on a hard level surface.

The units LP-gas tank shall be shut OFF when not in use.

The unit shall not be used if wind velocity is more than 10 mph to prevent flame-out
After use the unit shall be allowed to cool for 20 minutes before handling.

The unit shall be used outdoors in a well-ventilated area.

The unit shall NOT be handled while in use.

The unit shall be placed to prevent casual contact to the public/children.

The unit shall be placed at least 5' from any flammable materials such as carpet, drapes, decorations, chemicals, paper goods, furniture and all building structures.

Fire Extinguishers must be located within 25' of heater.

Tanks shall be store at least 5' from any doorway, building structure and doorway
Heaters must auto turnoff if tipped over.

ANY QUESTIONS PLEASE REACH OUT TO OUR
FIRE MARSHAL AT 973-292-6602